

Test Certificate

THE SOUTHERN
PAT COMPANY LTD
EXAMPLE
TEST RESULTS



The Southern Pat Company Limited

Portable Appliance Test Engineers

Tests Conducted By: The Southern PAT Company Limited, Oaklands House, 86 Highdown, Worcester Park, Surrey, KT4 7JB

On Behalf Of: Your Company Name, Burden Lane, Belmont, Sutton, Surrey, SM2 7DD

Site: Your Location

Location: Your Post Code

Asset: 20001

Description: AC POWER ADAPTER

Test	Result	Unit	Status
Visual			Pass
Insulation Resistance	> 199	MOhm	Pass
Live Voltage	239	V	Information
Neutral Voltage	5	V	Information
Touch Current	< 0.07	mA	Pass

Comments:

Overall Status: Pass

Date Of Test: 21/01/2021

Test Instrument: PrimeTest 300 X39-0051

Tested By: Tspcl

Test Engineer: S.T Aldred

THE SOUTHERN
PAT COMPANY LTD
EXAMPLE
TEST RESULTS

Concise Test History



The Southern Pat Company Limited

Portable Appliance Test Engineers

Test Status: All, Test Type: All
From: 21/01/2021 To: 12/02/2021

Asset ID	Description	User	Test Instrument	Date	Result
20001	AC POWER ADAPTER	SPCL SA005	X39-0051	21/01/2021	Pass
20002	4G EXT LEAD	SPCL SA005	X39-0051	21/01/2021	Pass
20003	BUSH TV	SPCL SA005	X39-0051	21/01/2021	Pass
20004	IEC POWER LEAD	SPCL SA005	X39-0051	21/01/2021	Pass
20005	IEC POWER LEAD	SPCL SA005	X39-0051	21/01/2021	Pass
20006	MULTI PLUG ADAPTER	SPCL SA005	X39-0051	21/01/2021	Pass
20007	BAIN MARRIE	SPCL SA005	X39-0051	21/01/2021	Pass
20008	4G EXT LEAD	SPCL SA005	X39-0051	21/01/2021	Pass
20009	AC POWER ADAPTER	SPCL SA005	X39-0051	21/01/2021	Pass
20010	AC POWER LEAD	SPCL SA005	X39-0051	21/01/2021	Pass
20011	SAMSUNG TV	SPCL SA005	X39-0051	21/01/2021	Pass
20012	SAMSUNG TV	SPCL SA005	X39-0051	21/01/2021	Pass
20013	1G EXT LEAD	SPCL SA005	X39-0051	21/01/2021	Pass
20014	AC POWER LEAD	SPCL SA005	X39-0051	21/01/2021	Pass
20015	AC POWER ADAPTER	SPCL SA005	X39-0051	21/01/2021	Pass
20016	IEC POWER LEAD	SPCL SA005	X39-0051	21/01/2021	Pass
20017	AC POWER ADAPTER	SPCL SA005	X39-0051	21/01/2021	Pass
20018	CCTV / VDU / MONITOR	SPCL SA005	X39-0051	21/01/2021	Pass
20019	4G EXT LEAD	SPCL SA005	X39-0051	21/01/2021	Pass
20020	AC POWER LEAD	SPCL SA005	X39-0051	21/01/2021	Pass
20021	SAMSUNG TV	SPCL SA005	X39-0051	21/01/2021	Pass
20022	PDQ CHARGER	SPCL SA005	X39-0051	21/01/2021	Pass
20023	AC POWER LEAD	SPCL SA005	X39-0051	21/01/2021	Pass
20024	LABLE PRINTER	SPCL SA005	X39-0051	21/01/2021	Pass
20025	AC POWER ADAPTER	SPCL SA005	X39-0051	21/01/2021	Pass
20026	4G EXT LEAD	SPCL SA005	X39-0051	21/01/2021	Pass
20027	IEC POWER LEAD	SPCL SA005	X39-0051	21/01/2021	Pass
20028	IEC POWER LEAD	SPCL SA005	X39-0051	21/01/2021	Pass
20029	AC POWER ADAPTER	SPCL SA005	X39-0051	21/01/2021	Pass
20030	AC POWER ADAPTER	SPCL SA005	X39-0051	21/01/2021	Pass
20031	4G EXT LEAD	SPCL SA005	X39-0051	21/01/2021	Pass
20032	AC POWER ADAPTER	SPCL SA005	X39-0051	21/01/2021	Pass
20033	MULTIPLUG ADAPTER	SPCL SA005	X39-0051	21/01/2021	Pass
20034	TOUCH SCREEN VDU	SPCL SA005	X39-0051	21/01/2021	Pass
20035	SPRINT FRIDGE	SPCL SA005	X39-0051	21/01/2021	Pass
20036	SPRINT FRIDGE	SPCL SA005	X39-0051	21/01/2021	Pass
20037	IEC POWER LEAD	SPCL SA005	X39-0051	21/01/2021	Pass
20038	AC POWER CHARGER	SPCL SA005	X39-0051	21/01/2021	Pass
20039	AC POWER LEAD	SPCL SA005	X39-0051	21/01/2021	Pass
20040	AC POWER ADAPTER	SPCL SA005	X39-0051	21/01/2021	Pass
20041	AC POWER ADAPTER	SPCL SA005	X39-0051	21/01/2021	Pass
20042	UNIFY SWITCH	SPCL SA005	X39-0051	21/01/2021	Pass
20043	SPRINT FRIDGE	SPCL SA005	X39-0051	21/01/2021	Pass
20044	LABLE PRINTER	SPCL SA005	X39-0051	21/01/2021	Pass
20045	TOUCH SCREEN VDU	SPCL SA005	X39-0051	21/01/2021	Pass
20046	PCS PAGER CHARGER	SPCL SA005	X39-0051	21/01/2021	Pass
20047	AC POWER ADAPTER	SPCL SA005	X39-0051	21/01/2021	Pass
20048	AC POWER ADAPTER	SPCL SA005	X39-0051	21/01/2021	Pass
20049	IEC POWER LEAD	SPCL SA005	X39-0051	21/01/2021	Pass
20050	IEC POWER LEAD	SPCL SA005	X39-0051	21/01/2021	Pass
20051	AC POWER ADAPTER	SPCL SA005	X39-0051	21/01/2021	Pass
20052	IEC POWER LEAD	SPCL SA005	X39-0051	21/01/2021	Pass
20053	MULTIPLUG ADAPTER	SPCL SA005	X39-0051	21/01/2021	Pass
20054	MULTIPLUG ADAPTER	SPCL SA005	X39-0051	21/01/2021	Pass
20055	MIKO COFFEE UNIT	SPCL SA005	X39-0051	21/01/2021	Pass
20056	MIKO COFFEE UNIT	SPCL SA005	X39-0051	21/01/2021	Pass
20057	IEC POWER LEAD	SPCL SA005	X39-0051	21/01/2021	Pass
20058	AC POWER CHARGER	SPCL SA005	X39-0051	21/01/2021	Pass
20059	LINGAT WATER BOILER	SPCL SA005	X39-0051	21/01/2021	Pass
20060	PAVELLY COFFEE UNIT	SPCL SA005	X39-0051	21/01/2021	Pass
20061	IEC POWER LEAD	SPCL SA005	X39-0051	21/01/2021	Pass
20062	DUCALE COFFEE UNIT	SPCL SA005	X39-0051	21/01/2021	Pass
20063	SPRINT FRIDGE	SPCL SA005	X39-0051	21/01/2021	Pass
20064	DISPLAY FRIDGE	SPCL SA005	X39-0051	21/01/2021	Pass
20065	BAIN MARRIE	SPCL SA005	X39-0051	21/01/2021	Pass
20066	NELSON GLASS WASHER	SPCL SA005	X39-0051	21/01/2021	Pass
20067	TOUCH SCREEN VDU	SPCL SA005	X39-0051	21/01/2021	Pass
20068	AC POWER ADAPTER	SPCL SA005	X39-0051	21/01/2021	Pass
20069	LABLE PRINTER	SPCL SA005	X39-0051	21/01/2021	Pass
20070	IEC POWER LEAD	SPCL SA005	X39-0051	21/01/2021	Pass
20071	IEC POWER LEAD	SPCL SA005	X39-0051	21/01/2021	Pass

Detailed Latest Test Results

Test Status: All, Test Type: All



The Southern Pat Company Limited

Portable Appliance Test Engineers

Client: Your Company Name	Site: Your Location	Location: Your Post Code		
Asset ID: 20001	Description: AC POWER ADAPTER	User: Tspcl ; Test Instrument: X39-0051		
Test Type	Date	Result	Unit	Status
Visual	21/01/2021			Pass
Insulation Resistance	21/01/2021	> 199	MOhm	Pass
Live Voltage	21/01/2021	238	V	Information
Neutral Voltage	21/01/2021	5	V	Information
Touch Current	21/01/2021	< 0.07	mA	Pass
Overall: Pass				
Asset ID: 20002	Description: 4G EXT LEAD	User: Tspcl ; Test Instrument: X39-0051		
Test Type	Date	Result	Unit	Status
Visual	21/01/2021			Pass
Earth Continuity	21/01/2021	0.09	ohm	Pass
Insulation Resistance	21/01/2021	> 199	MOhm	Pass
Live Voltage	21/01/2021	238	V	Information
Neutral Voltage	21/01/2021	5	V	Information
PE Conductor Current	21/01/2021	< 0.15	mA	Pass
Overall: Pass				
Asset ID: 20003	Description: BUSH TV	User: Tspcl ; Test Instrument: X39-0051		
Test Type	Date	Result	Unit	Status
Visual	21/01/2021			Pass
Insulation Resistance	21/01/2021	> 199	MOhm	Pass
Live Voltage	21/01/2021	237	V	Information
Neutral Voltage	21/01/2021	5	V	Information
Touch Current	21/01/2021	< 0.07	mA	Pass
Overall: Pass				
Asset ID: 20004	Description: IEC POWER LEAD	User: Tspcl ; Test Instrument: X39-0051		
Test Type	Date	Result	Unit	Status
Visual	21/01/2021			Pass
IEC Lead Continuity	21/01/2021	0.022	ohm	Pass
Insulation Resistance	21/01/2021	> 199	MOhm	Pass
IEC Lead Polarity	21/01/2021			Pass
Overall: Pass				
Asset ID: 20005	Description: IEC POWER LEAD	User: Tspcl ; Test Instrument: X39-0051		
Test Type	Date	Result	Unit	Status
Visual	21/01/2021			Pass
IEC Lead Continuity	21/01/2021	0.022	ohm	Pass
Insulation Resistance	21/01/2021	> 199	MOhm	Pass
IEC Lead Polarity	21/01/2021			Pass
Overall: Pass				
Asset ID: 20006	Description: MULTI PLUG ADAPTER	User: Tspcl ; Test Instrument: X39-0051		
Test Type	Date	Result	Unit	Status
Visual	21/01/2021			Pass
Insulation Resistance	21/01/2021	> 199	MOhm	Pass
Live Voltage	21/01/2021	238	V	Information
Neutral Voltage	21/01/2021	5	V	Information
Touch Current	21/01/2021	< 0.07	mA	Pass
Overall: Pass				
Asset ID: 20007	Description: BAIN MARRIE	User: Tspcl ; Test Instrument: X39-0051		
Test Type	Date	Result	Unit	Status
Visual	21/01/2021			Pass
Earth Continuity	21/01/2021	0.062	ohm	Pass
Insulation Resistance	21/01/2021	> 199	MOhm	Pass
Live Voltage	21/01/2021	238	V	Information
Neutral Voltage	21/01/2021	5	V	Information
PE Conductor Current	21/01/2021	< 0.15	mA	Pass
Overall: Pass				
Asset ID: 20008	Description: 4G EXT LEAD	User: Tspcl ; Test Instrument: X39-0051		
Test Type	Date	Result	Unit	Status
Visual	21/01/2021			Pass
Earth Continuity	21/01/2021	0.06	ohm	Pass
Insulation Resistance	21/01/2021	> 199	MOhm	Pass

THE SOUTHERN
PAT COMPANY LTD
EXAMPLE
TEST RESULTS

THE SOUTHERN
PAT COMPANY LTD
EXAMPLE
TEST RESULTS

Detailed Test History



The Southern Pat Company Limited

Portable Appliance Test Engineers

Page 1
Wednesday, 3 March 2021 12:10

Test Status: All, Test Type: All
Person: All, Instrument: All
From: 21/01/2021 To: 12/02/2021

Client: Your Company Name	Site: Your Location	Location: Your Post Code		
Asset ID: 20001	Description: AC POWER ADAPTER	User: SPCL SA005	Test Instrument: X39-0051	
Test Type	Date	Result	Unit	Status
Visual	21/01/2021			Pass
Insulation Resistance	21/01/2021	> 199	MOhm	Pass
Live Voltage	21/01/2021	239	V	Information
Neutral Voltage	21/01/2021	5	V	Information
Touch Current	21/01/2021	< 0.07	mA	Pass
Overall: Pass				
Asset ID: 20002	Description: 4G EXT LEAD	User: SPCL SA005	Test Instrument: X39-0051	
Test Type	Date	Result	Unit	Status
Visual	21/01/2021			Pass
Earth Continuity	21/01/2021	0.09	ohm	Pass
Insulation Resistance	21/01/2021	> 199	MOhm	Pass
Live Voltage	21/01/2021	236	V	Information
Neutral Voltage	21/01/2021	5	V	Information
PE Conductor Current	21/01/2021	< 0.15	mA	Pass
Overall: Pass				
Asset ID: 20003	Description: BUSH TV	User: SPCL SA005	Test Instrument: X39-0051	
Test Type	Date	Result	Unit	Status
Visual	21/01/2021			Pass
Insulation Resistance	21/01/2021	> 199	MOhm	Pass
Live Voltage	21/01/2021	237	V	Information
Neutral Voltage	21/01/2021	5	V	Information
Touch Current	21/01/2021	< 0.07	mA	Pass
Overall: Pass				
Asset ID: 20004	Description: IEC POWER LEAD	User: SPCL SA005	Test Instrument: X39-0051	
Test Type	Date	Result	Unit	Status
Visual	21/01/2021			Pass
IEC Lead Continuity	21/01/2021	0.022	ohm	Pass
Insulation Resistance	21/01/2021	> 199	MOhm	Pass
IEC Lead Polarity	21/01/2021			Pass
Overall: Pass				
Asset ID: 20005	Description: IEC POWER LEAD	User: SPCL SA005	Test Instrument: X39-0051	
Test Type	Date	Result	Unit	Status
Visual	21/01/2021			Pass
IEC Lead Continuity	21/01/2021	0.022	ohm	Pass
Insulation Resistance	21/01/2021	> 199	MOhm	Pass
IEC Lead Polarity	21/01/2021			Pass
Overall: Pass				
Asset ID: 20006	Description: MULTI PLUG ADAPTER	User: SPCL SA005	Test Instrument: X39-0051	
Test Type	Date	Result	Unit	Status
Visual	21/01/2021			Pass
Insulation Resistance	21/01/2021	> 199	MOhm	Pass
Live Voltage	21/01/2021	236	V	Information
Neutral Voltage	21/01/2021	5	V	Information
Touch Current	21/01/2021	< 0.07	mA	Pass
Overall: Pass				
Asset ID: 20007	Description: BAIN MARRIE	User: SPCL SA005	Test Instrument: X39-0051	
Test Type	Date	Result	Unit	Status
Visual	21/01/2021			Pass
Earth Continuity	21/01/2021	0.062	ohm	Pass
Insulation Resistance	21/01/2021	> 199	MOhm	Pass
Live Voltage	21/01/2021	238	V	Information
Neutral Voltage	21/01/2021	5	V	Information
PE Conductor Current	21/01/2021	< 0.15	mA	Pass
Overall: Pass				
Asset ID: 20008	Description: 4G EXT LEAD	User: SPCL SA005	Test Instrument: X39-0051	
Test Type	Date	Result	Unit	Status
Visual	21/01/2021			Pass
Earth Continuity	21/01/2021	0.06	ohm	Pass
Insulation Resistance	21/01/2021	> 199	MOhm	Pass
Live Voltage	21/01/2021	239	V	Information
Neutral Voltage	21/01/2021	5	V	Information
PE Conductor Current	21/01/2021	< 0.15	mA	Pass

**THE SOUTHERN
PAT COMPANY LTD
EXAMPLE
TEST RESULTS**

**THE SOUTHERN
PAT COMPANY LTD
EXAMPLE
TEST RESULTS**

THE SOUTHERN
PAT COMPANY LTD
EXAMPLE
TEST RESULTS

CERTIFICATION



**CLASS 1 & 2 PORTABLE APPLIANCE TESTING
TO COMPLY WITH GOVERNMENT HEALTH AND SAFETY
LEGISLATION & REGULATIONS**

**THIS IS TO CERTIFY THAT ON THE 22ND JANUARY 2021
ELECTRICAL APPLIANCE TESTING
WAS COMPLETED ON 1909 APPLIANCES.**

**IN ACCORDANCE WITH THE INSTITUTION OF ELECTRICAL
ENGINEER'S CODE OF PRACTICE FOR IN-SERVICE
INSPECTION AND TESTING.**

**FOR – :- YOUR BUSINESS NAME
COOPERS HILL
NUTFIELD
SURREY
UK
RH4 8HY**

CLASS 1 EXPIRY DATE 22ND JANUARY 2021

CLASS 2 EXPIRY DATE 22ND AUGUST 2021

AUTHORISED SIGNATORY

S.T. Scott

CERTIFICATE NUMBER - TSPCL20216428

**THIS CERTIFICATE HAS BEEN ISSUED ACCORDING TO THE CONDITIONS AND NOTES ON THIS CD
COPIES OF THE PAT TEST LOGS ARE AVAILABLE FROM THE SOUTHERN PAT COMPANY LTD
OAKLANDS HOUSE HIGHDOWN, WORCESTER PARK, SURREY KT8 9JB
TEL 020 8224 1426 · EMAIL · SOUTHERNPAT@BTINTERNET.COM**



THE SOUTHERN
PAT COMPANY LTD
EXAMPLE
TEST RESULTS